



DATE : March 2, 1989

TO : 822 File

FROM : W. E. Schwartz *WES*

SUBJECT : Georgetown Tanks Removal
Underground Tanks - 1988 Program
Specification No. 2928

The following people met in Room 202 on 3-1-89 at 1:00 p.m. to discuss the tank removals at Georgetown Steam plant:

John Summers
Al Critz
Ed Chu
Ron Welch
Bill Briggs

Gene Wang
Bill Schwartz
Shirli Axelrod
Kamol Lekhakul

John Summers presented an overview of Removal Plans 1 and 2. No formal rejection was sent to the contractor for Plan 1. Plan 2 arrived after Plan 1 objections were voiced to the contractor. Unit 822 approved Plan 2. EAD rejected Plan 2 on the basis that vacuum removal of PCB sludge by Fuel Processors was unacceptable. Fuel Processors/Bill Briggs said that PCBs would be burnt in Ashgrove cement plant at Woodland, WA. Shirli Axelrod said this incineration plan is unacceptable.

Shirli Axelrod said that removal of sludge according to Plan 1 and tank removal by Plan 2 is acceptable. John Summers said the acceptable features of both plans would be posted approved to the contractor.

Regarding the Idaho forms John Summers instructed Shirli Axelrod to complete them and prepare manifest for shipment of tanks and drums to EnviroSafe Services of Idaho. Kamol Lekhakul said he would supply manifest forms.

The bunker oil contaminated soil for the other tanks will be set aside for later disposition. Tank removal to begin 3-2-89.

WES:rtb

SCL 04172